Indicazioni sul comportamento in caso di incendio

Comportamento corretto in caso di incendio, incidente chimico o rilascio di vapori tossici (emergenza) nelle vicinanze di un'abitazione con impianto di ventilazione meccanica controllata

Non si può mai escludere che nelle vicinanze della propria casa/appartamento avvenga un incidente con fuoriuscita di gas o fumo. Nella maggior parte dei casi, la radio, la polizia o i soccorritori forniscono indicazioni sul comportamento da tenere. Spesso tali comunicazioni sono accompagnate dalla raccomandazione di chiudere porte e finestre.

Se si utilizza un sistema di ventilazione meccanica con ventilatori o dispositivi passivi (solitamente ALD), attenersi alle seguenti istruzioni:

- Chiudere manualmente i pannelli delle prese d'aria esterne (aperture di immissione).
- Una volta chiusi tutti gli elementi, entrerà nell'edificio circa la stessa quantità d'aria che penetra attraverso le finestre chiuse. Una tenuta d'aria al 100 % non è consentita per motivi di sicurezza e non è necessaria.
- Spegnere tutti i dispositivi di ventilazione, se possibile. Farlo tramite l'interruttore del dispositivo oppure disattivando l'alimentazione dal quadro elettrico.
- Non ostruire mai meccanicamente gli apparecchi di ventilazione (ad es. non inserire asciugamani o simili nelle griglie).
- Se i ventilatori sono collegati all'accensione della luce in bagno/WC/cucina o a sensori di movimento, evitare di attivarli (tenere la luce spenta o coprire il sensore).

Particolarità della serie e², AB 30/60, RA 15-60

Questi dispositivi possono essere chiusi rimuovendo manualmente il pannello interno (come avviene durante la pulizia del filtro) e reinserendolo ruotato di 180°. In questo modo il passaggio d'aria viene completamente bloccato. Sul lato interno del pannello è presente una breve istruzione. Sul sito internet www.lunos.it sono inoltre disponibili guide per la chiusura dei singoli apparecchi.



Non dimenticate di riaprire tutti gli elementi e di riattivare i ventilatori. In caso contrario, il sistema di ventilazione non funzionerà più correttamente.



Naturalmente ci auguriamo che non si verifichi mai una situazione del genere e che il vostro impianto di ventilazione meccanica controllata non debba essere disattivato.

Il vostro team LUNOS

Behavior in case of fire

Correct behaviour in the case of a fire, chemical accident or toxic vapours (average) in the vicinity of a dwelling unit with controlled home ventilation system

It can never be avoided that an accident with escaping gases or smoke occurs near your house/apartment. In most cases, the radio or the police or rescue services will give advice on how to behave in this situation. Often the messages are accompanied by a request that windows and doors of the flat/house should be closed.

If you use a mechanical ventilation system with fans or passive ventilation devices (mostly ALD), please proceed as follows:

- Close the shutters of the supply air openings (fresh air diffusers) manually (see right).
- When all elements are closed, about as much air still enters the building as through closed windows. One hundred percent airtightness is not permitted by the legislator for safety reasons and is also not required.
- If possible, switch off all ventilation units. Either via the control switch on the ventilation unit or via a fuse in the electrical installation distributor.
- Never block the ventilation units mechanically (e.g. do not put towels or similar in the ventilation slots).
- If your fans are connected to the light in the bathroom/WC/kitchen or similar or have motion detectors, try not to switch on the fans if possible (leave the light switched off or cover the motion detector).

Special features of the e² series, AB 30/60, RA 15-60

These can be closed by manually removing the inner cover (as when cleaning a filter) and turning it 180° to put it back on. The air diffuser is then completely closed. There are brief instructions on the inside of the inner cover. You can also find instructions for closing the individual units on the Internet at www.lunos.de/en.



Please do not forget to open all elements again and to switch the fans back into working order. Otherwise your ventilation system will no longer function correctly.



Of course, we wish you that such a situation never occurs and that your controlled residential ventilation system does not have to be switched off.

Your LUNOS team